

# Fire Curtain Safety and Usage Information Sheet

## Fire Curtain Basics

- Make sure everyone on stage is properly trained on how and when to deploy the fire curtain.
- Remember to close your fire curtain anytime the facility is not in use.
  - NFPA 80, Chapter 21, Section 7.1.1
- Always keep the proscenium line clear so the fire curtain can close. This means scenery, and props cannot be directly under the fire curtain even during performances.

## Testing and Inspection

- Once every 90 days you should test the emergency closure.
  - NFPA 80, Chapter 21, Section 7.1.3
  - Name and contact information of Fire Marshall/Code Official \_\_\_\_\_
- Annually inspection fire curtain inspection is required by ANSI and NFPA and should be done in conjunction with you complete rigging system inspection.
  - ANSI E1.47 - NFPA 81, Chapter 21, Section 9.1 – ANSI E1.22-12.4
  - Name and contact information of Rigging Inspector \_\_\_\_\_

## How to Deploy the Fire Curtain

## How to Reset the Fire Curtain

## Log

Year	Task	Signature	Date
	Q1 Test		
	Q2 Test		
	Q3 Test		
	Q4 Test		
	Inspection		
	Q1 Test		
	Q2 Test		
	Q3 Test		
	Q4 Test		
	Inspection		

Year	Task	Signature	Date
	Q1 Test		
	Q2 Test		
	Q3 Test		
	Q4 Test		
	Inspection		
	Q1 Test		
	Q2 Test		
	Q3 Test		
	Q4 Test		
	Inspection		



### Minnesota Location

Wenger Phone 800.4WENGER (493-6437) Wenger Worldwide +1.507.455.4100 | Parts & Service 800.887.7145 | wengercorp.com  
GearBoss Phone 800.493.6437 | gearboss.com  
555 Park Drive, PO Box 448 | Owatonna | MN 55060

### New York Location

J.R. Clancy Phone 800.836.1885 JR Clancy Worldwide +1.315.451.3440 | jrclancy.com | 7041 Interstate Island Road | Syracuse | NY 13209